

TO: ALL BIDDERS

10th June, 2020

Dear Sir/Madam,

ADDENDUM 2: CLARIFICATION

**TENDER DEESCRPTION: TENDER FOR SUPPLY & DELIVERY OF STORES
CONSTRUCTION MATERIALS TO GDC KABARAK SITE IN NAKURU. (RESERVED FOR
WOMEN) - TENDER NO: GDC/SC/OT/041/2019:2020**

In response to bidder's request for clarification, GDC wishes to respond as follows: -

No.	Bidders Query	GDC Response
1.	Item No. 12, Machine Cut Stone 225*225, Please share the complete measurements	The measurements provided are complete, the length of a masonry block is standard (400mm) and therefore no additional information is required. This is informed by the total area requested of 1400 square meters
2.	Item No. 17, Ballast, what is the required size.	Required size is 20mm

All other instructions including the **closing date of 16th June 2020 at 2:00pm** remain unchanged.

Yours faithfully,



DORIS KYAKA

MANAGER, SUPPLY CHAIN

FOR: GEOTHERMAL DEVELOPMENT COMPANY LIMITED