

19<sup>th</sup> June 2023

TO: ALL BIDDERS

**ADDENDUM 2: CLARIFICATION & EXTENSION OF CLOSING DATE**

**RE: TENDER FOR SUPPLY OF SPARES, TOOLS AND CONSUMABLES FOR THE WATER SUPPLY SYSTEM IN BARINGO - TENDER NO. GDC/INFRA/OT/063/2022-2023**


In response to the request for clarification & extension of closing date, GDC wishes to respond as follows;

No.	Bidders Query	GDC Response
1.	Please share the technical specifications for the a) Denso Tape 10m x 50mm <sup>2</sup> (the work it will be used for since the several of the same dimensions i.e those can with stand high temperatures other are bituminous)	High Temperature
2.	Complete tool box for electrical tool box fully equipped (the tool box are several, please share what the tool box should include) there is 11.96,36 or .52 piece tool boxes	52 Pieces
3.	Portable DC hipot tester please share more specifications for this to get the right they are several in the market.	Phenix 4160-5B-230 Portable DC Hipots 160 kVDC 5mA with Beaglebone 230 Volt Or equivalent
4.	caution notices (safety warning) what should be written on them	Danger- High voltage – Keep off
5.	Request for Extension of Tender Closing Date	The tender closing date is hereby extended from 20 <sup>th</sup> June 2023 to <b>27<sup>th</sup> June 2023 at 2.00Pm.</b>



All other requirements/instructions remain unchanged.

Yours faithfully,



**DORIS KYAKA**  
**MANAGER, SUPPLY CHAIN**