

30th April 2024

To: All Bidders

ADDENDUM 1: CLARIFICATION

TENDER FOR SUPPLY & DELIVERY OF WELL TESTING EQUIPMENT AND ACCESSORIES FOR BARINGO-SILALI GEOTHERMAL PROJECT - REF: GDC/GRM/OT/059/2023:2024

In response to bidders request for clarification, GDC wishes to respond as follows;

No.	SUBJECT	BIDDER'S QUESTION	GDC'S RESPONSE
1	Delivery Period	Please clarify if the delivery period is within six (6) months or one (1) year	Within six (6) Months
2	Wire Reinforced steam Gaskets	Kindly confirm the specific thickness required for item No. 14 Wire Reinforced Steam Gasket 4ft x 8ft.	3mm

All other requirements/instructions including the tender closing date of **7th May 2024 at 11.00am** remain unchanged.

Yours faithfully,



PAMELA OUMA
PRINCIPAL OFFICER, STORES AND LOGISTICS
FOR: GEOTHERMAL DEVELOPMENT CO. LIMITED.