

13th September 2023

TO: ALL BIDDERS

ADDENDUM 1: CLARIFICATION

**TENDER FOR SUPPLY OF 8 INCH VICTAULIC WATER PIPELINE FITTINGS & ACCESSORIES –
REF: GDC/INFRA/OT/011/2023:2024**

In response to the request for clarification, GDC wishes to respond as follows.

No.	Bidder's Question	GDC Response
1	According to the schedule of Requirements <i>Item No. 4. 8" Steel Elbows</i> , you have indicated: "i. 22.5 Degrees Long Radius Elbows ii. 45 degrees short radius elbows bevel edged: iii. 90 degrees short radius elbows bevel edged" . Kindly provide the required brand, thickness, and the standard material for the 8" Steel Elbows.	1. Quote for Any brand 2. Steel elbow thickness: 6.35mm Standard material: Carbon Steel
2	According to the Schedule of Requirements <i>Item No. 2-4</i> Kindly provide the required brand, thickness, and the standard material for the 8" Flanged Cast Steel Gate Valves, 8" Forged Steel Weld Neck Flanges and 8" Steel Elbows.	1. No specific brand 2. Standard material as per GDC specifications
3	Please clarify whether the price schedules as they appear in the tender document are correct you have given them as unit price, unit 16% vat, unit price include of VAT it seems they are wrong or you want to tabulate our prices this way	Enclosed as Annex find amended price schedule

All other requirements/instructions including the tender closing/opening date of **Friday 13th September 2023 at 11.00am** remain unchanged.

Yours faithfully,



DORIS KYAKA
MANAGER, SUPPLY CHAIN