

8<sup>th</sup> April 2024

REF: GDC/MSC/005/23-24/pk-im

**TO: ALL BIDDERS**

Dear Sir,

**ADDENDUM 1 – CLARIFICATION**

**RE: TENDER FOR SUPPLY AND DELIVERY OF LIGHTING CONSUMABLES FOR BARINGO-SILALI GEOTHERMAL PROJECT (RE-TENDER) – TENDER REFERENCE No. GDC/DEM/OT/044/2023-2024.**

In response to bidder's request for clarification, GDC wishes to provide the following response;

No.	Bidder's Request	GDC Response
1.	We wish to seek clarification on the technical specifications of the first three items of SCHEDULE 3: CIRCUIT BREAKERS, CONTACTORS, RELAYS AND FUSES. The manufacturers would like to know whether the MCCBs required are 3Pole or 4Pole.	The breakers required should be complete 3 Pole 3d fixed circuit breakers designed to optimize space and breaking capacity.
2.	The above tender is closing on 11 <sup>th</sup> April 2024. Considering there is a holiday (To mark the end of Ramadhani), looming around that date with the uncertainty of the exact holiday date, could you consider extending the closing date by a week, so as, you can allow bidders to confidently apply bid securities with clear date.	The Tender closing date has been extended from Thursday 11 <sup>th</sup> April 2024 at 11.00 am to <b>Thursday 18<sup>th</sup> April, 2024 at 11:00am.</b>

NB: All other requirements/instructions remain unchanged.

Yours faithfully,



**PATRICK KAPTO**  
Ag. MANAGER, SUPPLY CHAIN  
**FOR: GEOTHERMAL DEVELOPMENT COMPANY**