

7<sup>th</sup> November 2023

REF: GDC/MS/005/23-24/dk-fk

**TO: ALL BIDDERS**

Dear Sir,

**ADDENDUM 3: CLARIFICATION**

**RE: RE: TENDER FOR THE SUPPLY AND DELIVERY OF SOLAR FLOOD LIGHTING SYSTEM FOR BARINGO-SILALI GEOTHERMAL FIELD (RESERVED FOR YOUTH'S ONLY) - GDC/DEM/OT/025/2023:2024.**

In response to the bidder's request for clarification, GDC wishes to provide the following response.

S.N	BIDDER'S REQUEST	GDC'S RESPONSE
1.	For the battery construction, do you require lead-acid batteries or lithium iron phosphate (LiFePO4) batteries?	Lithium Iron Phosphate battery (LiFePO4 battery)
2.	Kindly clarify if the floodlight wattage is 1000 watts as a 30ah battery is too small to power 1000 watts.	Lithium Iron Phosphate (LiFePO4) 30Ah and above.
3.	Request for Tender closing date extension	<b>Tender closing date extended to 16th November 2023 at 11:00am</b>

NB: All other instructions remain unchanged.

Yours faithfully,



**DORIS KYAKA**  
**MANAGER, SUPPLY CHAIN**  
**FOR: GEOTHERMAL DEVELOPMENT COMPANY**